

2015 Annual Drinking Water Quality Report

Town of St. Paul, Virginia

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.

Our water source is the Clinch River. The Clinch River is a surface water source that originates in Tazewell County Virginia and meanders through Russell, Wise, and Scott Counties in Virginia before entering Tennessee.

The Virginia Department of Health conducted a source water assessment of our system during 2002. The Clinch River has been determined to be of high susceptibility to contamination using the criteria developed by the state in its approved Source Water Assessment Program. The assessment report consists of maps showing the source water assessment area, an inventory of known land use activities of concern, and documentation of any known contamination within the last five (5) years. The report is available by contacting Earl Carter at the phone number or address given elsewhere in this drinking water quality report. The report will also be available at the St. Paul Town Hall, located at 16531 Russell Street.

If you have any questions about this report or concerning your water utility, please contact Earl Carter Director of Public Works, at 276-762-9683. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled Town Council meetings. Meetings are held on the third Monday of each month at 6:00 PM in the Town Hall. The Town Hall is located at 16531 Russell Street.

The Town of St. Paul Water Treatment Plant routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2015.

All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Picocuries per liter (pCi/L) - Picocuries per liter is a measure of the radioactivity in water.

Nephelometric Turbidity Unit (NTU) - nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level Goal or MRDLG – The level of drinking water disinfectant below, which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Maximum Residual Disinfectant Level or MRDL – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Action Level – The concentration of a contaminant, which, if exceeded, triggers treatment or other requirements, which a water system must follow.

We have learned through our monitoring and testing that some constituents have been detected.

TEST RESULTS Regulated Contaminants							
Contaminant (Units)	Violation Y/N	Level Detected	Range	MCLG	MCL	Typical Source of Contamination	Date
Turbidity (NTU)	No	< 0.3 100% of the time	N/A	N/A	TT, < 0.3 NTU 95%	Soil runoff	2015
Turbidity (NTU)	No	0.08	0.05-0.08	N/A	TT 1 NTU MAXIMUM	Soil runoff	2015
Alpha emitters (Pci/l)	No	<0.9	N/A	0	15	Erosion of natural deposits	02-11 2014
Combined Radium (Pci/l)	No	<0.7	N/A	0	5	Erosion of natural deposits	02-11 2014
Barium (ppm)	No	0.037	N/A	2	2	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits	01-20 2015
Fluoride (ppm)	No	<0.2	N/A	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories	04-15 2015
Nitrate plus Nitrite Nitrogen (ppm)	No	0.76	N/A	10	10	Runoff from fertilizer use; leaching from septic tanks, seag; erosion of natural deposits	02-20 2015
TEST RESULTS Disinfectants/Disinfection by-products							
Contaminant (Units)	Violation Y/N	Level Detected	Range	MCLG	MCL	Typical Source of Contamination	Date
Chlorine (ppm)	No	1.39	1.1 – 2.1	MRDLG 4	MRDL 4	Water additive used to control microbes	2015
** Haloacetic Acids (ppb)	No	** TBD To be Determined	27	N/A	60	By-product of drinking water disinfection	07-14 2015
** Total Trihalomethane (ppb)	No	** TBD To be Determined	41	N/A	80	By-product of drinking water disinfection	07-14 2015
Total Organic Carbon Removal atio	No	1.28	1.00-2.14	N/A	TT In Compliance If > or =1.0 or Alternate criteria is met	Naturally Present in the environment	2015
** Haloacetic Acids and Total Trihalomethane level detected is based on a running annual average and at this time we have not completed four quarters of sampling, so compliance cannot be determined.							

The water quality results in the above table are from testing done in 2015. However, the state allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though accurate, is more than one year old.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include: (1) Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; (2) Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming; (3) Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses; (4) Organic chemical contaminants, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems. (5) Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Town of St. Paul Virginia waterworks is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline 800-426-4791 or at <http://www.epa.gov/safewater/lead>

MCLs are set at very stringent levels by the U.S. Environmental Protection Agency. In developing the standard EPA assumes the average adult drinks 2 liters of water each day throughout a 70-year life span. EPA generally sets MCLs at level that will result in no adverse health effects for some contaminants or a one-in-ten-thousand to a one-in-a-million chance of having the described health effect for other contaminants.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

In our continuing efforts to maintain a safe and dependable water supply it may be necessary to make improvements in your water system. The costs of these improvements may be reflected in the rate structure. Rate adjustments may be necessary in order to address these improvements.

We at the Town of St. Paul Water Treatment Plant work constantly to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

If I can assist you in any way please contact me at 276-762-9683.

Earl Carter

Director of Public Works
Town of St. Paul, Virginia

Source Water Protection Tips

- Eliminate excess use of lawn and garden fertilizers and pesticides – they contain hazardous chemicals that can reach your drinking water source.
- Pick up after your pets.
- If you have your own septic system, properly maintain your system to reduce leaching to water sources or consider connecting to a public water system.
- Dispose of chemicals properly; take used motor oil to a recycling center.
- Volunteer in your community. Find a watershed or wellhead protection organization in your community and volunteer to help. If there are no active groups, consider starting one. Use EPA's Adopt Your Watershed to locate groups in your community, or visit the Watershed Information Network's How to Start a Watershed Team.
- Organize a storm drain stenciling project with your local government or water supplier. Stencil a message next to the street drain reminding people "Dump No Waste - Drains to River" or "Protect Your Water." Produce and distribute a flyer for households to remind residents that storm drains dump directly into your local water body.

Water Conservation Tips

Did you know that the average U.S. household uses approximately 400 gallons of water per day or 100 gallons per person per day? Luckily, there are many low-cost and no-cost ways to conserve water. Small changes can make a big difference – try one today and soon it will become second nature.

- Take short showers - a 5 minute shower uses 4 to 5 gallons of water compared to up to 50 gallons for a bath.
- Shut off water while brushing your teeth, washing your hair and shaving and save up to 500 gallons a month.
- Use a water-efficient showerhead. They're inexpensive, easy to install, and can save you up to 750 gallons a month.
- Run your clothes washer and dishwasher only when they are full. You can save up to 1,000 gallons a month.
- Water plants only when necessary.
- Fix leaky toilets and faucets. Faucet washers are inexpensive and take only a few to replace. To check your toilet for a leak, place a few drops of food coloring in the tank and wait. If it seeps into the toilet bowl without flushing, you have a leak. Fixing it or replacing it with a new, more efficient model can save up to 1,000 gallons a month.
- Adjust sprinklers so only your lawn is watered. Apply water only as fast as the soil can absorb it and during the cooler parts of the day to reduce evaporation.
- Teach your kids about water conservation to ensure a future generation that uses water wisely. Make it a family effort to reduce next month's water bill!
- Visit www.epa.gov/watersense for more information.